

ANNEXURE C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE
No. _____ Date: _____

It is certified that an inspection team headed by Dr. Ajamal, Medical Officer from Primary Health Centre (PHC) inspected Presidency High School (Name & Address of the School: H.No. 1-20/11, Borgaon (P), Nizamabad, Telangana – 503230) on 07-08-2026 (date of inspection) and on the basis of the Water Test Report (Attached) bearing No. _____ dated 08-08-2026 of District Internal Water Quality Monitoring Laboratory (PHED Lab) certified that Presidency High School, H.No. 1-20/11, Borgaon (P), Nizamabad, Telangana – 503230 has safe drinking water facilities for the students and members of staff of the institution. The school also maintains hygienic sanitation conditions in the school building and campus as per the norms prescribed by the Central/State/U.T. Government.

This certificate is valid till: 06-08-2027

Signature with Seal _____

Name Dr. Ajamal

Designation: Medical Officer

Name and address of the office/department _____

Primary Health Centre (PHC)

N. Ajamal
Medical Officer
PHC: Mudakpally,
Dist. Nizamabad.(TG)

To:

The Principal

Presidency High School

H.No. 1-20/11, Borgaon (P),

Nizamabad, Telangana – 503230

GOVERNMENT OF TELANGANA
Mission Bhagiratha Department
District Internal Water Quality Monitoring Laboratory Nizamabad at Z.P. Campus-503002
Report on Chemical Analysis of Drinking water.

Collection Date :-22-11-2025

Received Date :-22-11-2025

Village :- Presidency School, Nizamabad

Mandal :-Nizamabad

Division :- Nizamabad

Dist :- Nizamabad

Desirable Limit	6.5 to 8.5	1	1	—	500	200	300	75	250	1.0	45	0.30	30	150
Maximum permissible limit in absence of alternative Source	No Relation	15	5	—	2000	600	600	200	1000	1.5	No Relation	1.00	100	400

Lr. No.	Source	Village & Location	pH	Colour	Turbidity (NTUS)	EC	Total Dissolved Solids	Alkalinity (as CaCO ₃) P M	Total Hardness (CaCO ₃)	Calcium as CaCO ₃	Chlorides as (Cl)	Fluoride as (F)	Nitrates as (No.3)	Iron as Fe	Meg-necium Mg.	Sulph-ates So ₄	REMARKS
1	2	3	4	5	6		8	9 10	11	12	13	14	15	16	17	18	19
1	BW	Presideny School, Nizamabad.	7.31	-	-	185	120	Nil 120	116	32	28	0.17	1.4	0.04	20	22	Satisfactory

Note : 1) All Standards are expressed in mg/litre except pH, Colour, EC and Turbidity.
 2) Standards as per Bureau of Indian Standards I.S. 10500 : 2012

Chemist/Microbiologist

Consultant (Water Quality)
 District Lab Nizamabad,
 District Lab Nizamabad.